

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/08/2012  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155718</b>		(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b> B. WING _____		(X3) DATE SURVEY COMPLETED  <b>08/02/2012</b>	
NAME OF PROVIDER OR SUPPLIER  <b>COMMUNITY NORTHVIEW CARE CENTER</b>				STREET ADDRESS, CITY, STATE, ZIP CODE <b>1235 W CROSS ST ANDERSON, IN 46011</b>			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	<p>INITIAL COMMENTS</p> <p>A Quality Assurance Walk-thru Survey was conducted by the Indiana State Department of Health.</p> <p>Survey Date: 08/02/12</p> <p>Facility Number: 000562 Provider Number: 155718 AIM Number: 100267150</p> <p>Surveyor: Phillip Komsiski, Life Safety Code Specialist</p> <p>At this Quality Assurance Walk-thru survey, Community Northview Care Center was found in compliance with 410 IAC 16.2-3.1-19(ff).</p> <p>This one story facility was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors and battery powered smoke detectors in all resident rooms. The facility has a capacity of 101 and had a census of 75 at the time of this survey.</p> <p>The facility was found in compliance with state law in regard to sprinkler coverage and smoke detector coverage.</p> <p>All areas where the residents have customary access were sprinklered. The facility had one detached garage and one barn for facility storage which were not sprinklered.</p> <p>Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 08/07/12.</p>			K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/08/2012  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155718</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01</b> B. WING _____		(X3) DATE SURVEY COMPLETED  <b>08/02/2012</b>
NAME OF PROVIDER OR SUPPLIER  <b>COMMUNITY NORTHVIEW CARE CENTER</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>1235 W CROSS ST ANDERSON, IN 46011</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	